

**Maximum Contaminant Level Violation  
MCL, LRAA/ TOTAL HALOACETIC ACIDS (HAA5)**

The Texas Commission on Environmental Quality (TCEQ) has notified the City of Wills Point public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total haloacetic acids. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total haloacetic acids to be 0.060 milligrams per liter (mg/L) based on a locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total haloacetic acids indicates a compliance value for quarter 2 2021 of 189.0 mg/L at sample point q2114846002, Corner Lybrand St/Austin Ave., Wills Point, TX 75169.

Haloacetic acids are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

Corrected injection points which immediately lowered MCL, LRAA to below 0.060 milligrams per liter (mg/L),  
Flushed entire system to comply with U.S. EPA established compliance value and retested at sample points.

---

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact **Brent Holbrook** at 214-536-6772.

City of Wills Point PWS

Posted /Delivered on: 10-8-21

**Maximum Contaminant Level Violation**  
**MCL, LRAA/ TOTAL HALOACETIC ACIDS (HAA5)**

The Texas Commission on Environmental Quality (TCEQ) has notified the City of Wills Point public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total haloacetic acids. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total haloacetic acids to be 0.060 milligrams per liter (mg/L) based on a locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total haloacetic acids indicates a compliance value for quarter 2 2021 of 175.0 mg/L at sample point Q2114846001, 410 VZCR 3428, Wills Point, TX 75169.

Haloacetic acids are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

Corrected injection points which immediately lowered MCL, LRAA to below 0.060 milligrams per liter (mg/L),  
Flushed entire system to comply with U.S. EPA established compliance value and retested at sample points.

---

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact **Brent Holbrook** at 214-536-6772.

City of Wills Point PWS

Posted /Delivered on: 10-8-21